

Film Fire / Life Safety Inspection Checklist

CHECK YES/NO

1. Access

- | | | |
|---|--------------------------|--------------------------|
| A. Fire lanes kept clear (20 feet wide) | <input type="checkbox"/> | <input type="checkbox"/> |
| B. Hydrants not blocked | <input type="checkbox"/> | <input type="checkbox"/> |
| C. Fire Department Connections Clear | <input type="checkbox"/> | <input type="checkbox"/> |
| D. Standpipe connections clear | <input type="checkbox"/> | <input type="checkbox"/> |

2. Parking

- | | | |
|---|--------------------------|--------------------------|
| A. Special Effects trucks parked in designated location | <input type="checkbox"/> | <input type="checkbox"/> |
| B. Refueler Vehicles parked in designated locations | <input type="checkbox"/> | <input type="checkbox"/> |
| C. All vehicles parked minimum 20 feet from tents | <input type="checkbox"/> | <input type="checkbox"/> |
| D. Catering Trucks parked in designated locations | <input type="checkbox"/> | <input type="checkbox"/> |
| E. Generator truck parked in designated location | <input type="checkbox"/> | <input type="checkbox"/> |
| F. Water tenders parked in designated locations | <input type="checkbox"/> | <input type="checkbox"/> |
| G. Dry vegetation cleared from designated parking areas | <input type="checkbox"/> | <input type="checkbox"/> |

3. Exiting

- | | | |
|---|--------------------------|--------------------------|
| A. All designated exits kept clear | <input type="checkbox"/> | <input type="checkbox"/> |
| B. Exits visible | <input type="checkbox"/> | <input type="checkbox"/> |
| C. No flammable liquids, LPG or pyrotechnics near an exit | <input type="checkbox"/> | <input type="checkbox"/> |

4. Pyrotechnic Special Effects

- | | | |
|--|--------------------------|--------------------------|
| A. Pyrotechnician in possession of proper license | <input type="checkbox"/> | <input type="checkbox"/> |
| B. Permit on site | <input type="checkbox"/> | <input type="checkbox"/> |
| C. Fire department briefed on proposed activity | <input type="checkbox"/> | <input type="checkbox"/> |
| D. Alternative means of protection provided | <input type="checkbox"/> | <input type="checkbox"/> |
| E. Special Effects in Class II Magazine or Department of Transportation Carton | <input type="checkbox"/> | <input type="checkbox"/> |
| F. Fire extinguishment provided by pyrotechnician | <input type="checkbox"/> | <input type="checkbox"/> |
| G. Extinguishment equipment charged and in good working order | <input type="checkbox"/> | <input type="checkbox"/> |

5. Flammable Liquids and Gases

CHECK YES/NO

- | | | |
|--|--------------------------|--------------------------|
| A. Proper storage in approved containers | <input type="checkbox"/> | <input type="checkbox"/> |
| B. Pressure vessels identified as to contents | <input type="checkbox"/> | <input type="checkbox"/> |
| C. Pressure vessels secured | <input type="checkbox"/> | <input type="checkbox"/> |
| D. Approved hoses and valves for pressurised gases | <input type="checkbox"/> | <input type="checkbox"/> |
| E. Flammable liquids and gases kept away from heat sources | <input type="checkbox"/> | <input type="checkbox"/> |
| F. No refuelling of equipment while in operation | <input type="checkbox"/> | <input type="checkbox"/> |
| G. Refuelling done in remote area | <input type="checkbox"/> | <input type="checkbox"/> |
| H. Aircraft refuelled in designated site on location | <input type="checkbox"/> | <input type="checkbox"/> |
| I. Supply and receiving vessels bonded together | <input type="checkbox"/> | <input type="checkbox"/> |
| J. No leakage of fuels from generator | <input type="checkbox"/> | <input type="checkbox"/> |
| K. Spray painting and lacquer application performed safely | <input type="checkbox"/> | <input type="checkbox"/> |
| L. Proper ventilation to prevent flammable vapours from accumulating | <input type="checkbox"/> | <input type="checkbox"/> |

6. Electrical and Lighting

- | | | |
|---|--------------------------|--------------------------|
| A. Cords and connections in good condition (no deterioration) | <input type="checkbox"/> | <input type="checkbox"/> |
| B. Extension cords not used as substitute for permanent wiring of building | <input type="checkbox"/> | <input type="checkbox"/> |
| C. A/C properly grounded | <input type="checkbox"/> | <input type="checkbox"/> |
| D. Generators attended to and in good repair | <input type="checkbox"/> | <input type="checkbox"/> |
| E. Generators grounded | <input type="checkbox"/> | <input type="checkbox"/> |
| F. Cables properly protected, bundled, and kept as clear as possible at exits | <input type="checkbox"/> | <input type="checkbox"/> |
| G. Combustible materials kept clear of light fixtures | <input type="checkbox"/> | <input type="checkbox"/> |

7. Welding, Cutting and Grinding

- | | | |
|---|--------------------------|--------------------------|
| A. Combustible materials within 10 feet of welding relocated or covered | <input type="checkbox"/> | <input type="checkbox"/> |
| B. Flammable liquids removed from area where grinding sparks are produced | <input type="checkbox"/> | <input type="checkbox"/> |
| C. Fire extinguishers provided on welding set | <input type="checkbox"/> | <input type="checkbox"/> |

8. Smoking

- | | | |
|--|--------------------------|--------------------------|
| A. Smoking prohibited near pyrotechnic special effects storage, or flammable liquids storage and dispensing area | <input type="checkbox"/> | <input type="checkbox"/> |
| B. Designated smoking areas, if any, clearly marked | <input type="checkbox"/> | <input type="checkbox"/> |
| C. NO SMOKING signs prominently visible where smoking is prohibited | <input type="checkbox"/> | <input type="checkbox"/> |

9. Miscellaneous

- | | | |
|--|--------------------------|--------------------------|
| A. Film permit on site | <input type="checkbox"/> | <input type="checkbox"/> |
| B. All sprinkler and standpipe systems fully operational | <input type="checkbox"/> | <input type="checkbox"/> |



CHECK YES/NO

- | | | |
|---|--------------------------|--------------------------|
| C. Extinguishers present and ready for use | <input type="checkbox"/> | <input type="checkbox"/> |
| D. Methods of reporting an emergency available | <input type="checkbox"/> | <input type="checkbox"/> |
| E. Catering trucks provided with fire extinguishers | <input type="checkbox"/> | <input type="checkbox"/> |
| F. Light combustibles in carpenter shop and other work areas removed frequently | <input type="checkbox"/> | <input type="checkbox"/> |
| G. Tent materials flame retardant | <input type="checkbox"/> | <input type="checkbox"/> |
| H. Fabrics, draperies etc. flame retardant | <input type="checkbox"/> | <input type="checkbox"/> |
| I. Brush cleared adequately at outdoor filming locations | <input type="checkbox"/> | <input type="checkbox"/> |
| J. Open burning in compliance with all regulations | <input type="checkbox"/> | <input type="checkbox"/> |
| K. Helistop clearly delineated and adequately cleared | <input type="checkbox"/> | <input type="checkbox"/> |
| L. Bleachers and grandstands constructed to withstand loads imposed | <input type="checkbox"/> | <input type="checkbox"/> |
| M. Greens (trees, bushes, etc.), if not fresh or live, flame retardant | <input type="checkbox"/> | <input type="checkbox"/> |

10. Required Permits and/or Certificates

- | | | |
|---|--------------------------|--------------------------|
| A. Film Permit | <input type="checkbox"/> | <input type="checkbox"/> |
| B. Special Effects (pyrotechnic or non-pyrotechnic) | <input type="checkbox"/> | <input type="checkbox"/> |
| C. Refueler vehicle | <input type="checkbox"/> | <input type="checkbox"/> |
| D. Welding and/or cutting | <input type="checkbox"/> | <input type="checkbox"/> |
| E. Tent | <input type="checkbox"/> | <input type="checkbox"/> |
| F. Flame retardant | <input type="checkbox"/> | <input type="checkbox"/> |